

27 March, 2025

Procedure No. 25001975

Goods: Firefight Monitors

Please see below EAPC clarifications and replies to questions and comments received from potential participants:

EAPC replies and clarifications below become an integral part of this Tender and will force the bidders.

EAPC Replies

| | Question | Reply |
|----|--|---|
| 1. | The company whose equipment we are offering is still in the process of receiving FM approval and probably will not have the approval by the time the bid is submitted | Not approved. The quote should be according to the Technical Specification. |
| | Requesting your comment | |